

Statement of Conformity

Floor coverings – Determination of the anti-slip properties

Statement no.: P282138233

Name and address of the manufacturer:

ACCIAI SPECIALI TERNI S.p.A.
Viale B. Brin, 218
05100 Terni
ITALY

We hereby state, that the mentioned below has been tested in accordance with the test methods specified in the technical specification, confirming its intended use in working areas with slipping hazards, in which the **evaluation group R11 / V** is required

Tested according to:

DIN 51130 : 2009
BGR 181

Test report no.:

201223826/3210 IFA test certificate dtd 05.11.2010

Description of product /
Type designation:

Pickled stainless steel plate "MANDORLATO"
In acc. to ASTM A240/ASTM A793: AISI 304 e
AISI 316 L

Manufacturing plant.:

ACCIAI SPECIALI TERNI S.p.A.
Viale B. Brin, 218
05100 Terni
ITALY

Ponte di Piave, 2013-03-28



Arduino Giorgio Piva
Material Surveyor

A handwritten signature in blue ink, appearing to read "Arduino", is written over a horizontal line.

TÜV Rheinland-Certification Body for
Pressure Equipment
TÜV Rheinland Industrie Service GmbH
Notified Body, ID-No. 0035
Am Grauen Stein, D-51105 Köln

TÜV Rheinland Italia
Via Italia 1, I - 24030 Medolago (BG)
Tel. +39 035 4933147, e-mail: bergamo@it.tuv.com

D-006-Rev7

www.tuv.com

 **TÜVRheinland®**
Precisely Right.